

Notice Notice Notice

September 20, 2019

Cooper Road Trailer Park

Public Water Supply

Fed ID Number: NY1302125

On September 6, 2019, the chlorine disinfection system for this water supply was not operating during a Health Department inspection. The drinking water regulations require that this notice be made to inform all water consumers of the Public Health Hazard.

As a community public water supply, the Health Department has determined that this water system is required to provide disinfection to provide safe drinking water. Water that is not disinfected can contain disease-causing bacteria.

Disease-causing organisms in drinking water can cause symptoms that include diarrhea, cramps, nausea, and possibly jaundice, and associated headaches and fatigue. These symptoms, however, are not just associated with disease-causing organisms in drinking water, but also may be caused by a number of factors other than your drinking water.

The following steps are being taken to correct the problem:

The owner was directed to repair or service the chlorine disinfection system. Due to inaction of the owner, this order will remain in effect until further notice. Due to the owner's inaction, the Health Department has authorized the Dutchess County Water & Wastewater Authority to act as the interim operator.

Preventative measures you should take:

NYS certified bottled water should be used for drinking, food preparations, beverages, and the making of ice.

For further information please contact:

Operator: Dutchess County Water & Wastewater Authority: 845-486-3601

Dutchess County Dept. of Behavioral & Community Health: 845-486-3404