GRAVELLESS and ALTERNATE AGGREGATE PRODUCTS **February 2015**

The NYS Department of Health has determined that the following products comply with 10 NYCRR Appendix 75-A. This Department does not approve proprietary products, but will review products as a courtesy.

Manufacturer	Product	Trench Length Design (75-A: Tables 4A or 4B)[1,2]
Advanced Drainage Systems (ADS) www.ads-pipe.com	GEO-Flow Pipe Leaching System GEO-Flow geotextile sand filter system	25% 6.0 ft^2/ft rating
Cultec www.cultec.com	Contractor EZ-24 Chamber Contractor 100 Chamber Contractor 125 Chamber	1:1 25% 25%
Eljen Corporation www.eljen.com	Geotextile Sand Filter (Type B) Geotextile Sand Filter (Model A425)	6.0 ft^2/ft rating 6.0 ft^2/ft rating
Infiltrator Systems www.infiltratorsystems.com *ARC Chambers may be marketed as Advanced Drainage Systems (ADS) products; ADS is owned by Infiltrator.	ATL System ATL Geotextile Sand Filter System Equalizer 24 Quick 4 Equalizer 24 Quick4 Equalizer 24 HD Quick4 Equalizer 24 LP Quick 4 Equalizer 36 Quick4 Plus Equalizer 36 LP Quick4 Standard Quick4 Plus Standard Quick4 Plus Standard LP High Capacity H-20 EZ Flow 1202H EZ Flow 1203T EZ Flow 1003T BioDiffuser 15" Narrow (Bio 2) BioDiffuser 22" Narrow (Bio 3) ARC 18 Chamber* ARC 24 Chamber* ARC 36 Chamber* ARC 36 HC Chamber* ARC 36 HC H-20 Chamber* BioDiffuser 11" Standard (34" wide) BioDiffuser 16" High Capacity H-20 Flowtech by Infiltrator: FTS 122H-1 Flowtech by Infiltrator: FTS 123T-1 Flowtech by Infiltrator: FTS 103T-1	25% 6.0 ft^2/ft rating 1:1 1:1 1:1 1:1 25% 1:1 25% 25% 25% 25% 1:1 25% 25% 1:1 25% 1:1 25% 25% 25% 25% 25% 25% 1:1 25% 25%
Geomatrix LLC www.geomatrixsystems.com	GST Leaching System	1:1
Presby Environmental www.presbyeco.com	Enviro-Septic System AES geotextile sand filter system	25% 6.0 ft^2/ft rating
Modern Landfill www.moderncorporation.com	Tire Derived Aggregate (TDA)[3]	1:1
Casing, Inc. Jim.fabrizio@casingsinc.com	Tire Derived Aggregate (TDA)[3]	1:1

[1] Reductions in total linear feet based on criteria in Appendix 75-A, subsection 75-A.8(c)
[2] The trench length reductions are not applicable at properties located within the New York City Watershed
[3] The TDA product meets criteria established in Section 75-A.8(b)(3)(v)

Note: *The above list is not an endorsement of any of the products by the NYS Department of Health, nor is it intended to represent a comprehensive list of all products that comply with 10 NYCRR Appendix 75-A. This list will be occasionally updated as new product specifications are reviewed. The use of these products may be subject to approvals by local government agencies, including local health departments, watersheds or other local agencies.*