

Analyte and MCL list (as of August 2007)

Analyte	MCLValue	Units
benzene	5	ug/L
bromobenzene	5	ug/L
bromochloromethane	5	ug/L
bromomethane	5	ug/L
n-butylbenzene	5	ug/L
sec-butylbenzene	5	ug/L
tert-butylbenzene	5	ug/L
carbon tetrachloride	5	ug/L
chlorobenzene	5	ug/L
chloroethane	5	ug/L
chloromethane	5	ug/L
2-chlorotoluene	5	ug/L
4-chlorotoluene	5	ug/L
dibromomethane	5	ug/L
1,2-dichlorobenzene	5	ug/L
1,3-dichlorobenzene	5	ug/L
1,4-dichlorobenzene	5	ug/L
dichlorodifluoromethane	5	ug/L
1,1-dichloroethane	5	ug/L
1,2-dichloroethane	5	ug/L
1,1-dichloroethene	5	ug/L
cis-1,2-dichloroethene	5	ug/L
trans-1,2-dichloroethene	5	ug/L
1,2-dichloropropane	5	ug/L
1,3-dichloropropane	5	ug/L
2,2-dichloropropane	5	ug/L
1,1-dichloropropene	5	ug/L
cis-1,3-dichloropropene	5	ug/L
trans-1,3-dichloropropene	5	ug/L
ethylbenzene	5	ug/L
hexachlorobutadiene	5	ug/L
isopropylbenzene	5	ug/L
p-isopropyltoluene	5	ug/L
methylene chloride	5	ug/L
n-propylbenzene	5	ug/L
styrene	5	ug/L
1,1,1,2-tetrachloroethane	5	ug/L
1,1,2,2-tetrachloroethane	5	ug/L
tetrachloroethene	5	ug/L
toluene	5	ug/L
1,2,3-trichlorobenzene	5	ug/L
1,2,4-trichlorobenzene	5	ug/L
1,1,1-trichloroethane	5	ug/L
1,1,2-trichloroethane	5	ug/L
trichloroethene	5	ug/L
trichlorofluoromethane	5	ug/L
1,2,3-trichloropropane	5	ug/L
1,2,4-trimethylbenzene	5	ug/L
1,3,5-trimethylbenzene	5	ug/L
o-xylene	5	ug/L
m,p-xylene	5	ug/L
methyl-tertiary-butyl-ether	10	ug/L
vinyl chloride	2	ug/L
alkalinity		mg/L
antimony	0.006	mg/L
arsenic	0.01	mg/L
barium	2	mg/L
beryllium	0.004	mg/L
cadmium	0.005	mg/L
chloride	250	mg/L
chromium	0.1	mg/L
cyanide	0.2	mg/L

Analyte	MCLValue	Units
hardness		mg/L
iron	0.3	mg/L
lead	0.015	mg/L
manganese	0.3	mg/L
mercury	0.002	mg/L
nickel		mg/L
nitrate	10	mg/L
nitrite	1	mg/L
pH		unitless
selenium	0.05	mg/L
sodium		mg/L
sulfate	250	mg/L
thallium	0.002	mg/L
turbidity	5	NTU
total coliform	0	colonies/100ml
Escherichia coli	0	colonies/100ml

MCL = Maximum Contaminant Level

ug/L = micrograms/Liter

mg/L = milligrams/Liter

NTU = Nephelometric Turbidity Units

A blank field means that there is no MCL for the analyte.