

Annual Drinking Water Quality Report for 2017
Greenfields Water System
Cream Street, Hyde Park, NY 12538
(Public Water Supply ID# 1302794)

INTRODUCTION

To comply with State regulations, Greenfields Water, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, we conducted tests for many types of contaminants, we detected Iron and Manganese at levels higher than the State allows. Additional information on Iron and Manganese can be found under the section "What Does this Information Mean"? This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

The Greenfields Water System operations were turned over to the Dutchess County Water and Wastewater Authority on January 11, 2016. If you have any questions about this report or concerning your drinking water, please contact **Dutchess County Water & Wastewater Authority at (845)486-3601**. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled board meetings. They are generally held on the third Wednesday of each month. The meetings begin at 4:00 and take place in the second floor conference room at 27 High Street, Poughkeepsie, NY. Please call our office at 845-486-3601 for agenda details and any last minute meeting date or time changes.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves approximately 1050 people with 281 service connection. Our water source is four drilled rock wells which are located within our property boundary, near the water plant off Cream Street. The water is disinfected using sodium hypochlorite. We also add orthophosphate to the water for corrosion control and iron sequestration.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, synthetic organic compounds, and radiologicals. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Dutchess County Department of Behavioral and Community Health at (845) 486-3404.

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, AL or TT)	Likely Source of Contamination
Copper (1)	No	June 2015	0.699 Range = 0.058-0.802)	mg/L	1.3	1.3	Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives.
Lead (2)	No	June 2015	0.002 (Range = ND - 0.003)	mg/L	0	0.015	Corrosion of household plumbing systems; Erosion of natural deposits.
Arsenic Entry Point	No	10/17	0.0006	ug/L	n/a	10	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production waste
Barium Entry Point	No	10/17	0.1	mg/L	2	2	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits.
Barium Well 12	No	3/11/16	0.124	mg/L	2	2	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits.
Selenium	No	10/17	0.001	mg/l	n/a	0.05	Naturally occurring Erosion of natural deposits.
Thallium	No	10/17	0.00001	mg/l	n/a	0.002	Naturally occurring Erosion of natural deposits.
Chromium	No	10/17	.003	ug/L	n/a	100	Discharge from steel and pulp mills; Erosion of natural deposits
Nickel	No	10/17	.001	mg/L	n/a	n/a	Naturally occurring, by product of some manufacturing waste
Nitrate Entry Point	No	1/17	0.21	mg/L	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrate Well #12	No	1/17	<0.01	mg/l	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measure- ment	MCLG	Regulatory Limit (MCL, AL or TT)	Likely Source of Contamination
Iron Entry Point	No	Quarterly During 2017	0.121 Range = (<0.10 – 0.22)	mg/L	n/a	0.3	Naturally occurring
Manganese Entry Point	Yes	Quarterly During 2017	0.558 Range = (0.483 – 0.7)	mg/L	n/a	0.3	Naturally occurring; Indicative of landfill contamination.
Iron Well 12	Yes	Quarterly During 2017	1.565 Range = (0.53 – 3.14)	mg/L	n/a	0.3	Naturally occurring;
Manganese Well 12	Yes	Quarterly During 2017	126.03 Range = (0.69 – 502.0)	mg/L	n/a	0.3	Naturally occurring; Indicative of landfill contamination.
Iron Raw Well 9	No	2/25/2014 6/6/2014	0.150 0.037	mg/L	n/a	0.3	Naturally occurring;
Manganese Raw Well 9	No	2/25/2014 6/6/2014	1.05 0.914	mg/L	n/a	0.3	Naturally occurring; Indicative of landfill contamination.
Manganese Raw Well 10	No	2/25/2014 6/6/2014	0.188 0.132	mg/L	n/a	0.3	Naturally occurring; Indicative of landfill contamination.
Iron Raw Well 11	No	2/25/2014 6/6/2014	0.010 0.022	mg/L	n/a	0.3	Naturally occurring
Manganese Raw Well 11	Yes	2/25/2014 6/6/2014	0.484 0.409	mg/L	n/a	0.3	Naturally occurring; Indicative of landfill contamination
Haloacetic Acids	No	8/4/2015	2	ug/L	n/a	60	By-product of drinking water disinfection needed to kill harmful organisms.
Total Trihalomethanes	No	8/4/2015	14	mg/l	n/a	80	By-product of drinking water disinfection needed to kill harmful organisms.
Combined Radium 226 & 228 Entry Point	No	11/16	1.61	pCi/L	0	5	Erosion of Natural deposits
Gross Alpha Entry Point	No	11/16	4.53	pCi/L	0	15	Erosion of Natural deposits
Gross Alpha Well 12	No	7/16	2.7	pCi/L	0	15	Erosion of Natural deposits
Combined Radium 226 & 228 Well 12	No	7/17	1.88	pCi/L	0	5	Erosion of natural deposits.

Footnotes:

1. The level presented represents the 90th percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 10 samples were collected at your water system and the 90th percentile value is the reported value. The action level for copper was not exceeded at any of the sites tested.
2. The level presented represents the 90th percentile of the 10 samples collected. The action level for lead was not exceeded at any of the sites tested.

Definitions:

Non - Detects (ND) - Laboratory analysis indicates that the constituent is not present.

Milligrams per liter (mg/l) – Corresponds to one part of liquid in one million parts of liquid (parts per million – ppm).

Micrograms per liter (ug/l) – Corresponds to one part of liquid in one billion parts of liquid (parts per billion – ppb).

Action Level (AL) - The concentrations of a contaminant, which, if exceeded, triggers treatment, or other requirements, which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination

Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.

Health Effects for Iron- Iron has no health effects. At 1mg/l a substantial number of people will note the bitter astringent taste of iron. Also, at this concentration, it imparts a brownish color to laundered clothing and stains plumbing fixtures with characteristics rust color. Staining can result at levels of 0.05mg/l, lower than those detectable to taste buds. Therefore, the MCL of 0.3mg/l represents a reasonable compromise as adverse aesthetic effects are minimized at this level. Many multivitamins contain 3 or 4 milligrams of iron per capsule.

Health Effects for Manganese- The Food and Nutrition Board of the National Research Council determined an estimated safe and adequate daily dietary intake of manganese to be 2-5mg/l for adults. However, many peoples diet lead them to consume even higher amounts. The infant population is of greatest concern. It would be better if the drinking water were not used to make infant formula since it already contains iron and manganese. Excess manganese produces a brownish color in laundered goods and impairs the taste of tea, coffee, and other beverages. It may also cause a dark brownish or blackish stain on porcelain plumbing fixtures.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, the iron and manganese levels were high in some months throughout the year. The Dutchess County Water and Wastewater Authority continues to evaluate the water system and is currently implementing some steps to improve the water quality at the plant. This will reduce the amount of dirty water issues that have been present throughout the previous few years. In addition to the process changes at the plant, the operators have been and will continue to do more flushing from the hydrants as a way to remove old sediment from the distribution mains.

We are required to present the following information on lead in drinking water.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women, infants and young children. It is possible that lead levels at your home may higher than at other homes in the community as a

result of materials used in your home's plumbing. Greenfields Water is responsible for providing high quality drinking water, but can not control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2017, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ♦ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ♦ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ♦ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ♦ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ♦ Turn off the tap when brushing your teeth.
- ♦ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- ♦ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have any questions.